


Revision	Approved by	Number of Pages
000		30
Approval Date		
 <p>General Nuclear System Ltd.</p>		
<p>UK HPR1000 GDA Project</p>		
Document Reference:	HPR/GDA/PCSR/0033	
<p>Title:</p> <p style="text-align: center;">Pre-Construction Safety Report</p> <p style="text-align: center;">Chapter 33</p> <p style="text-align: center;">ALARP Evaluation</p>		
<p>This document has been prepared on behalf of General Nuclear System Limited (GNS) with the support of China General Nuclear Power Corporation (CGN) and Électricité de France S.A. (EDF).</p> <p>Although due care has been taken in compiling the content of this document, neither GNS, CGN, EDF nor any of their respective affiliates accept any liability in respect to any errors, omissions or inaccuracies contained or referred to in it.</p>		

DISTRIBUTION LIST

Recipients	Cross Box
GNS Executive	<input type="checkbox"/>
GNS all staff	<input type="checkbox"/>
GNS and BRB all staff	<input checked="" type="checkbox"/>
CGN	<input checked="" type="checkbox"/>
EDF	<input checked="" type="checkbox"/>
Regulators	<input checked="" type="checkbox"/>
Public	<input checked="" type="checkbox"/>

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 1 / 27

TABLE OF CONTENTS

33.1 List of Abbreviations and Acronyms.....	2
33.2 Introduction.....	4
33.2.1 Chapter Route Map.....	4
33.2.2 Chapter Structure.....	6
33.2.3 Interfaces with Other Chapters.....	7
33.3 Applicable Codes and Standards.....	10
33.4 ALARP Methodology for UK HPR1000.....	10
33.5 Historical Design Process.....	15
33.5.1 Historical Development from CPR1000 to ACPR1000.....	15
33.5.2 Historical Development of HPR1000 from ACPR1000.....	17
33.5.3 Conclusion on the Design Evolution.....	20
33.6 Preliminary ALARP Review of UK HPR1000.....	21
33.6.1 Holistic Review: Systematic Review of UK HPR1000 Design.....	21
33.6.1.1 Systematic Review of Design against RGP and OPEX.....	21
33.6.1.2 Insights from the PSA.....	21
33.6.2 Holistic Review: Collate Potential Improvements.....	21
33.6.3 Strategy for Specific Reviews and Iterative Holistic Evaluation.....	21
33.7 Assessments of Radiation Protection Targets.....	22
33.7.1 Assessment of Radiation Protection Targets for Normal Operation.....	22
33.7.2 Assessment of Radiation Protection Targets for Fault and Accident Condition ...	23
33.8 Concluding Remarks.....	26
33.9 References.....	26

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 2 / 27

33.1 List of Abbreviations and Acronyms

ACP	Auxiliary Control Panel
ACPR1000	Advanced Chinese Pressurised Reactor
ALARP	As Low As Reasonably Practicable
ASG	Emergency Feedwater System [EFWS]
ASP	Secondary Passive Heat Removal System [SPHRS]
BAT	Best Available Technique
BSL	Basic Safety Level
BSO	Basic Safety Objective
CGN	China General Nuclear Power Corporation
CIM	Component Interface Module
CPLD	Complex Programmable Logic Device
CPR1000	Chinese Pressurised Reactor
CPR1000 ⁺	Chinese Improved Pressurised Reactor
DiD	Defence in Depth
ECS	Extra Cooling System [ECS]
EDG	Emergency Diesel Generator
EHR	Containment Heat Removal System [CHRS]
GDA	Generic Design Assessment
HPR1000	Hua-long Pressurised Reactor
HPR1000 (FCG3)	Hua-long Pressurised Reactor under construction at Fangchenggang nuclear power plant unit 3
HVAC	Heating, Ventilation and Air Conditioning
I&C	Instrumentation and Control
ILW	Intermediate Level Waste
IVR	In-Vessel Retention
KDA	Severe Accident I&C System [SA I&C]
KDS	Diverse Actuation System [DAS]

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 3 / 27

KIC	Plant Computer Information and Control System [PCICS]
LLW	Low Level Waste
NNSA	National Nuclear Safety Administration
ONR	Office for Nuclear Regulation (UK)
OPEX	Operating Experience
PCER	Pre-Construction Environment Report
PCSR	Pre-Construction Safety Report
PSA	Probabilistic Safety Assessment
PSAS	Plant Standard Automation System
PZR	Pressuriser
RBS	Emergency Boration System [EBS]
RCP	Reactor Coolant System [RCS]
RGP	Relevant Good Practice
RIC	In-core Instrumentation System [IIS]
RIS	Safety Injection System [SIS]
RPS	Reactor Protection System
RPV	Reactor Pressure Vessel
RRI	Component Cooling Water System [CCWS]
SAP	Safety Assessment Principle (UK)
SAS	Safety Automation System
SBO	Station Black Out
SEC	Essential Service Water System [ESWS]
SG	Steam Generator
SGTR	Steam Generator Tube Rupture
TAG	Technical Assessment Guide (UK)
UK HPR1000	UK version of the Hua-long Pressurised Reactor
UPS	Uninterruptible Power Supply
VLLW	Very Low Level Waste

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 4 / 27

System codes (XXX) and system abbreviations (YYY) are provided for completeness in the format (XXX [YYY]), e.g. Containment Heat Removal System (EHR [CHRS]).

33.2 Introduction

Based upon the requirements of the *Health and Safety at Work etc. Act 1974* in Reference [1], as expressed in *Reducing Risks, Protecting People* in Reference [2] and the nuclear industry specific application in *The Tolerability of Risk from Nuclear Power Stations* in Reference [3], it is necessary to show that the nuclear safety risks to the workers and the public are As Low As Reasonably Practicable (ALARP).

The objective of this chapter is to summarise the ALARP evaluation for the UK version of the Hua-long Pressurised Reactor (UK HPR1000) design.

33.2.1 Chapter Route Map

Demonstrating that the nuclear safety risk is reduced to a level that is ALARP is essential to support the *Fundamental Objective* of UK HPR1000:

The *Fundamental Objective* of the UK HPR1000 is that: *The Generic UK HPR1000 could be constructed, operated, and decommissioned in the UK on a site bounded by the generic site envelope in a way that is safe, secure and that protects people and the environment.*

To underpin this objective, five high level claims (Level 1 claims) and a number of Level 2 claims are developed and presented in Chapter 1. This chapter supports *Claim 3.4* derived from high level *Claim 3*.

Claim 3: The design and intended construction and operation of the UK HPR1000 will protect the workers and the public by providing multiple levels of defence to fulfil the fundamental safety functions, reducing the nuclear safety risks to a level that is as low as reasonably practicable.

Claim 3.4: The safety assessment shows that the nuclear safety risks are ALARP.

To support the Claim 3.4, five arguments (which are also the sub-claims supporting Claim 3.4 in the Route Map) and their supporting evidence have been developed:

- a) *Argument 1: A suitable methodology has been adopted and implemented that helps reviewing the design and incorporating improvements that are reasonably practicable. The methodology has been outlined in Sub-chapter 33.4;*
 - 1) *Evidence 1.1: The ALARP Methodology document, Reference [4], has been issued to guide the ALARP demonstration for UK HPR1000;*
 - 2) *Evidence 1.2: The methodology has been applied in each topic area to support the production of the ALARP assessment reports for the topic areas, where the identification and review against Relevant Good Practice (RGP), identification of potential improvements, analysis of potential improvements,*

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 5 / 27

optioneering, etc., will be presented.

b) **Argument 2:** *A historic review of the Hua-long Pressurised Reactor (HPR1000) design shows that the HPR1000 is an optimised design. A summary of the historic review of the HPR1000 design is presented in Sub-chapter 33.5;*

1) **Evidence 2.1:** *The document HPR1000 R&D History, Reference [5], summarises the main design modifications from Chinese Pressurised Reactor (CPR1000) to HPR1000, demonstrating that the evolutionary design process of HPR1000 has led to an optimised and balanced design.*

c) **Argument 3:** *All reasonably practicable options to improve nuclear safety have been adopted, demonstrating that the risk is ALARP. The system design of UK HPR1000 will be reviewed to demonstrate that all reasonably practicable measures have been adopted to improve the design. Potential improvements and potential design changes that have been identified and considered will be discussed in Sub-chapter 33.6;*

1) **Evidence 3.1:** *The ALARP assessment reports for the topic areas summarise the ALARP assessments within the topic areas to analyse the potential improvements (if any) and to demonstrate that all reasonably practicable options have been implemented. The identification and analysis of potential improvements are on-going.*

d) **Argument 4:** *The radiological protection assessment demonstrates that the risk to workers and members of the public from the potential harmful effects of ionising radiation during normal operation complies with the associated UK legal requirements and is ALARP. A summary of the assessment is presented in Sub-Chapter 33.7, which forms an important part of the ALARP assessment for UK HPR1000;*

1) **Evidence 4.1:** *Radiation protection targets have been set out for normal operation, fault and accident conditions in the General Safety Requirements, Reference [6]. The radiation protection targets are consistent with the nine numerical targets provided in Safety Assessment Principles (SAPs), Reference [7]. Argument 4 will be supported by the assessment of radiation protection targets for normal operation (corresponding to the Targets 1 to 3 in SAPs) which will be addressed in Pre-Construction Safety Report (PCSR) Chapter 22 and Pre-Construction Environment Report (PCER) Chapter 7 Radiological Assessment, Reference [8].*

e) **Argument 5:** *The radiological protection assessment demonstrates that the risk to workers and members of the public from the potential harmful effects of ionising radiation resulting from fault and accident conditions complies with the associated UK legal requirements and is ALARP. A summary of the assessment will be presented in Sub-chapter 33.7, which forms an important part of the*

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 6 / 27

ALARP assessment for UK HPR1000.

*1) **Evidence 5.1:** This argument will be supported by the assessment of radiation protection targets for fault and accident condition (corresponding to the Targets 4 to 9 in SAPs) which will be addressed in Chapter 12 and Chapter 14. The assessments of the radiation protection targets for fault and accident condition will also rely on the analysis presented in Chapter 13 and Chapter 22..*

33.2.2 Chapter Structure

The general structure of this chapter is presented as follows:

a) Sub-chapter 33.1 List of Abbreviations and Acronyms:

This sub-chapter lists all the Abbreviations and Acronyms which are used in this chapter.

b) Sub-chapter 33.2 Introduction:

This sub-chapter gives a brief introduction to the chapter route map, structure and interfaces of this chapter.

c) Sub-chapter 33.3 Applicable Codes and Standards:

This sub-chapter presents the applicable codes and standards considered in the ALARP evaluation for UK HPR1000 design.

d) Sub-chapter 33.4 ALARP Methodology for UK HPR1000:

This sub-chapter outlines the ALARP methodology used for UK HPR1000, which supports the Argument 1 for this chapter.

e) Sub-chapter 33.5 Historical Design Process:

This sub-chapter reviews the historical development process for HPR1000 showing the rationale for major design characteristics, which supports Argument 2 for this chapter.

f) Sub-chapter 33.6 Preliminary ALARP Review of UK HPR1000:

This sub-chapter presents a summary of and the process that has been developed to identify potential improvements and consider reasonably practicable options to reduce the risk.

g) Sub-chapter 33.7 Assessments of Radiation Protection Targets:

This sub-chapter presents a summary of the findings from the evaluation of the radiation protection targets to confirm that the risks have been reduced to the levels that are ALARP.

h) Sub-chapter 33.8 Concluding Remarks:

This sub-chapter summarises the claims and arguments and presents the concluding remarks.

i) Sub-chapter 33.9 References:

This sub-chapter lists all the references supporting this chapter.

33.2.3 Interfaces with Other Chapters

The interfaces with other PCSR Chapters are listed in the following table.

T-33.2-1 Interfaces between Chapter 33 and Other Chapters

PCSR Chapter	Interface
Chapter 1 Introduction	Chapter 33 provides arguments and evidence to support the relevant nuclear safety claims presented in Chapter 1.
Chapter 4 General Safety and Design Principles	Chapter 4 presents general safety and design principles which are consistent with RGP and provides the radiation protection targets addressed in Chapter 33.
Chapter 5 Reactor Core	The ALARP approach presented in Chapter 33 has been applied in Chapters 5 to 11 to perform the ALARP demonstration for the structure, system and component designs, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 6 Reactor Coolant System	
Chapter 7 Safety Systems	
Chapter 8 Instrumentation and Control	
Chapter 9 Electric Power	
Chapter 10 Auxiliary Systems	
Chapter 11 Steam and Power Conversion System	
Chapter 12 Design Basis Condition Analysis	Chapter 12 provides the assessment of radiation protection targets for design basis conditions which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 13 Design Extension Conditions and Severe Accident Analysis	Chapter 13 provides the analysis of design extension conditions and severe accidents which support the assessment of radiation protection targets for fault and accident condition, which

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 8 / 27

PCSR Chapter	Interface
	will eventually support the overall ALARP demonstration addressed in Chapter 33.
Chapter 14 Probabilistic Safety Assessment	Chapter 14 provides the analysis of risk and the evaluation of radiation protection targets for fault and accident condition which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 15 Human Factors	Chapter 15 provides the assessment of human action impacting safety which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 16 Civil Works & Structures	ALARP analysis for civil structures by applying the ALARP methodology is provided by Chapter 16 to support the overall ALARP demonstration addressed in Chapter 33.
Chapter 17 Structural Integrity	ALARP analysis for structural integrity by applying the ALARP methodology is provided by Chapter 17 to support overall ALARP demonstration addressed in Chapter 33.
Chapter 18 External Hazards	Chapter 18 provides the ALARP analysis for external hazards protection by applying the ALARP methodology, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 19 Internal Hazards	Chapter 19 provides the ALARP analysis for internal hazards protection by applying the ALARP methodology, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 20 MSQA and Safety Case Management	The organisational arrangements and quality assurance arrangements set out in PCSR Chapter 20 are implemented in the design process and in the production of this chapter.
Chapter 21 Reactor Chemistry	Chapter 21 demonstrates that the chemistry aspects of the plant design have been developed to reduce the risk ALARP, which supports the

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 9 / 27

PCSR Chapter	Interface
	overall ALARP demonstration addressed in Chapter 33.
Chapter 22 Radiological Protection	Chapter 22 demonstrates that normal operation radiation doses to workers (for both internal and external doses) and to members of the public (from direct radiation) comply with UK legal requirements and are ALARP, supporting the overall ALARP demonstration addressed in Chapter 33.
Chapter 23 Radioactive Waste Management	The ALARP approach presented in Chapter 33 has been applied in Chapter 23 to perform the ALARP demonstration for radioactive waste management, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 24 Decommissioning	Chapter 24 demonstrates that risk during decommissioning will be reduced to the level that is ALARP, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 25 Conventional Safety and Fire Safety	Chapter 25 demonstrates that the conventional health and safety risks and fire safety risks are ALARP, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 28 Fuel Route and Storage	The ALARP approach presented in Chapter 33 has been applied in Chapters 28 to perform the ALARP demonstration for fuel route and storage, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 29 Interim Storage of Spent Fuel	The ALARP approach presented in Chapter 33 covers the ALARP approach adopted for the work included in PCSR Chapter 29, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 30 Commissioning	The ALARP approach presented in Chapter 33 has been applied in Chapter 30.
Chapter 31 Operational Management	Chapter 32 demonstrates that the safety risks are reduced to the level that is ALARP by applying

PCSR Chapter	Interface
	operational management, which supports the overall ALARP demonstration addressed in Chapter 33.
Chapter 32 Emergency Preparedness	The ALARP approach presented in Chapter 33 has been applied in Chapter 32.

33.3 Applicable Codes and Standards

For Generic Design Assessment (GDA), there is a fundamental requirement for the Requesting Party to set out the process to reduce risk to a level that is ALARP, Reference [7]. Demonstrating that risk has been reduced to a level that is ALARP is also a mandatory UK requirement. The following has been considered during the development of ALARP methodology and the ALARP demonstration of UK HPR1000:

- a) The Health and Safety at Work etc. Act, 1974;
- b) The Ionising Radiation Regulation, 1999;
- c) Management of Health and Safety at Work Regulations, 1999;
- d) Reducing Risks, Protecting People, 2001;
- e) The Tolerability of Risk from Nuclear Power Stations, 1992.

Moreover, *SAPs*, Reference [7], and the *Technical Assessment Guide (TAG)*, Reference [9], provide a useful insight for the Requesting Party to understand how a safety case is evaluated and specifically, how a proposed design is considered to have demonstrated the risk is ALARP. Therefore, the ALARP methodology is developed against the background of requirements from the *NS-TAST-GD-005: Guidance on the Demonstration of ALARP*, which gives detailed information about the requirements on ALARP demonstration.

33.4 ALARP Methodology for UK HPR1000

This sub-chapter outlines the methodology to the assessment of the generic design of the UK HPR1000 to determine whether the nuclear safety risks of the construction, operation and decommissioning are ALARP. The approach is developed against the background of the legal requirements and *SAPs*.

The ALARP process includes consideration of the four areas that are common to the demonstration of ALARP in the UK, Reference [9]:

- a) Comparison with RGP;
- b) Identification and evaluation of options (optioneering);

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 11 / 27

- c) Risk assessment, as a way of understanding the significance of the issue to the overall demonstration of ALARP;
- d) Implementation of all reasonably practicable improvements.

An overview of the ALARP approach is presented in F-33.4-1. There are three parts for the assessment:

- a) Part 1 is a holistic review, where the plant as a whole is reviewed to identify the areas for potential improvement;
- b) Part 2 is a specific review of each area for potential improvement to implement measures that are considered to be reasonably practicable;
- c) Part 3 is the holistic evaluation of whether the implementation of these improvements has reduced risks to levels that are ALARP and this requires iterations.

Part 1 is a holistic process aimed at identifying potential gaps along with their significance, and then identifying items for improvement (hereafter it is simply referred to as “potential improvements”). By looking at the design of the whole plant, the following steps are activities designed to identify potential improvements:

- a) Step 1: A review of the evolution of the HPR1000 design shall be carried out to demonstrate that safety improvements have been incorporated into the design, and that relevant Operating Experience (OPEX) has been considered. The historical review of HPR1000 is presented in Sub-chapter 33.5;
- b) Step 2: Systematic review of UK HPR1000 design is the step where the design of UK HPR1000 will be reviewed against RGP and OPEX to identify potential improvements. Once available, insights from Probabilistic Safety Assessment (PSA) will provide additional information on potential improvements. Step 2 is therefore divided into 2 sub-steps to address the holistic review from the two points of view discussed above:
 - 1) Step 2.1: Systematic review of design against RGP and OPEX, where RGP and OPEX shall be used as a basis for undertaking a review of the holistic design to identify potential improvements. The summary of the systematic review is presented in Sub-chapter 33.6 including the preliminary reviews against radiation protection targets and engineering principles;
 - 2) Step 2.2: Insights from the PSA of Hua-long Pressurised Reactor under construction at Fangchenggang nuclear power plant unit 3 (HPR1000 (FCG3)), and the subsequent development of the PSA model for UK HPR1000 will identify aspects of the plant where potential improvements will help reduce the overall plant risk.
- c) Step 3: Collate the potential improvements is the step where all of the identified

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 12 / 27

potential improvements following the Step 2 review shall be collected and managed according to the GDA configuration management procedures, References [10] and [11]. Potential improvements that have been identified will be presented in Sub-chapter 33.6.

When potential improvements are identified, these may be grouped for convenience and then processed through Steps 4 to 6 (Part 2), with an individual assessment produced for each potential improvement (or group of potential improvements):

- a) Step 4: Optioneering is the process of generation and evaluation of options which cope with the specific potential improvement. The following steps can be followed when performing the optioneering process:
 - 1) Define and characterise the specific potential improvement, where the fundamental issue, including its safety significance and potential implications (i.e. risk profile), should be understood and established;
 - 2) Develop the potential options to address the problem, where a broad range of options should be considered, by applying the Defence in Depth (DiD) principle, to take account of multiple factors to prevent, protect and mitigate the risk identified in the previous step;
 - 3) Assess the options (their benefits and dis-benefits), where each option should be evaluated systematically and where their relative merits should be identified. It is possible that this step may require a number of iterations as each option may require further information to support judgments made.
- b) Step 5: Implementation of reasonably practicable options, where the option(s) undertaken from Step 4 shall be considered for implementation or rejected for further analysis until a suitable solution is reached;
- c) Step 6: ALARP position justified for specific potential improvement, where a justification to explain the risk associated is judged to be lowered to a level that is ALARP at the time of assessment shall be provided.

The GDA configuration management procedures should include the verification of whether the design option chosen can reduce the risk to the level that is ALARP. The procedures should be followed when performing the potential design modifications.


The process of optioneering and implementation of the practicable options shall continue whilst there are potential areas for improvement (Part 3).

- a) Step 7: Holistic risk review: All items for improvement resolved? Once all of the potential improvements have been assessed, and a suitable (ALARP) solution has been implemented for each potential improvement, the design shall be subject to a further holistic review (Step 2.1 and Step 2.2), to identify any more potential improvements;

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 13 / 27

- b) Step 8: UK HPR1000 ALARP position reached. Where there are no further reasonably practicable options to implement, and no further identified areas for potential improvement, the design is considered as optimised, reflecting UK expectations, and the safety risk from the UK HPR1000 design is considered ALARP.

Further guidance is included in the *ALARP Methodology* document, Reference [4].



F-33.4-1 Overview of the UK HPR1000 ALARP Methodology

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 15 / 27

33.5 Historical Design Process

Following the ALARP methodology presented in Sub-chapter 33.4, the historical design process of the HPR1000 has been reviewed. Similar to the concept of ALARP, the idea of reducing risk and optimising the design was incorporated in the HPR1000 historical development, focussing notably on the design of the HPR1000 (FCG3). This sub-chapter summarises the historical development process, from the CPR1000 to Chinese Improved Pressurised Reactor (CPR1000⁺), Advanced Chinese Pressurised Reactor (ACPR1000) and finally the HPR1000. The historical process has been sub-divided into two phases:

- a) Continuous improvement of the second generation design, from CPR1000 to ACPR1000;
- b) Development of the Generation III HPR1000 from the ACPR1000.

33.5.1 Historical Development from CPR1000 to ACPR1000

In the 1980s, M310 nuclear reactor technology was imported in China from Framatome, France, and the first large commercial nuclear power plant was built in China, Daya Bay. Derived from the CPY three-loop design of Framatome, the M310 design has been modified in both safety and economic aspects to address the operational experience feedback from the Three Mile Island accident. The M310 design was considered as an advanced nuclear reactor design at that time.

Since then, continuous improvement and design modifications were performed. By considering operational experience feedback from similar nuclear power plants and applying new proven technologies and new codes and standards, a series of major modifications were determined and implemented to form the design of CPR1000. CPR1000 demonstrated a safer design. For example, the following safety related modifications were implemented, which are also considered in the HPR1000 design:

- a) Adoption of one-piece forging for Reactor Pressure Vessel (RPV) core shell to improve the mechanical properties by eliminating the circumferential welding in active area;
- b) Application of digital Instrumentation and Control (I&C) systems and an advanced main control room to provide improved human machine interface which reduce the risk of human errors;
- c) Addition of combustible gas control system to reduce the risk of hydrogen explosion.

In 2009, CPR1000⁺ design was established based on the CPR1000 design by implementing a number of major modifications with due consideration of improving the nuclear safety (especially in the aspects of severe accident mitigation), optimising the waste treatment design, improving the reliability and economics and facilitating

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 16 / 27

the operation and maintenance.

The following examples of the modifications are also inherited by the HPR1000 design:

- a) Application of In-Vessel Retention (IVR) strategy to prevent most ex-vessel phenomena which will challenge the integrity of containment under severe accident conditions;
- b) Optimisation of the hydrogen recombiner configuration to improve the reliability by applying the passive autocatalytic recombiner. The hydrogen concentration can be controlled under design basis conditions and design extension conditions to prevent hydrogen explosion and to ensure the containment integrity;
- c) Modifications to the radioactive waste treatment systems by applying new proven techniques to reduce the production of radioactive wastes;
- d) By optimising the habitable area and modifying the ventilation systems, the main control room habitability was improved, which eventually allowed for improved control of the reactor under severe accident conditions;
- e) Addition of safety classified and seismically qualified isolation valves for each train of main feedwater line to ensure the isolation of main feedwater, which reduces the release of mass and energy in the containment and helps to prevent the introduction of positive reactivity in the reactor core due to the overcooling of the primary circuit under fault and accident conditions.

On March 11, 2011, the well-known Great East Japan Earthquake and the subsequent Tsunami struck the Japan Fukushima Daiichi site, causing severe damage to the reactors. To sufficiently consider the lessons learnt from the Fukushima accident and to meet the new national requirements, China General Nuclear Power Corporation (CGN) proposed a number of major improvements based on the design of CPR1000⁺. The improvements were identified to address the lessons learnt from the Fukushima accident, such as the consistency review against the latest nuclear safety requirements, the insights from the full scope PSA. By implementing a number of modifications identified, the ACPR1000 design demonstrated higher reliability, safety and the ability to manage beyond design basis conditions similar to the Fukushima accident, which possessed the major safety characteristics of the Generation III nuclear power plant.

Notable examples of the major improvements are presented below:

- a) Addition of extra heat removal measures to cool the containment and the spent fuel pool under loss of ultimate heat sink condition, which corresponds to the Extra Cooling System (ECS [ECS]) of the UK HPR1000;
- b) Addition of Station Black Out (SBO) diesel generator to protect against the SBO condition. One SBO diesel generator was implemented for each unit, which

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 17 / 27

provides further DiD measures to ensure the reliability of the power supply under SBO;

- c) Addition of a severe accident dedicated valve performing the depressurisation of the primary circuit to prevent core melt under high pressure;
- d) Modification on the reactor coolant pump seal to ensure the integrity of the reactor coolant system in case of SBO;
- e) Addition of the Diverse Actuation System (KDS [DAS]) to cope with the software common cause failure on the Reactor Protection System (RPS);
- f) The Severe Accident I&C (KDA [SA I&C]) and the Uninterruptible Power Supply (UPS) were implemented to provide dedicated monitoring measures for severe accidents, which demonstrated the improved monitoring and control of the nuclear power plant.

Details about the modifications during the development from CPR1000 to ACPR1000 are presented in the *HPR1000 R&D History* document, Reference [5].

33.5.2 Historical Development of HPR1000 from ACPR1000

Based on the ACPR1000 design, a balanced Generation III HPR1000 was developed with due consideration of the development needs in internationalisation and the future reactor type upgrading. The HPR1000 design has succeeded the review held by National Nuclear Safety Administration (NNSA) and the Generic Reactor Safety Review held by IAEA.

Compared with the ACPR1000 design, the single-reactor scheme HPR1000 has better site foundation adaptability and higher safety and operating performance. It incorporates better the concept of defence in depth, and in particular, further strengthens the part concerning severe accidents prevention and mitigation. It makes full use of and integrates advanced design ideas of Generation III nuclear technologies; the experience of the design, construction, commissioning and operation regarding pressurised water reactors in China; and the achievements of nuclear power development and research in recent years. The following major design modifications have been implemented in the HPR1000 (FCG3):

a) Reactor Core

The reactor core of the HPR1000 design is composed of 177 advanced fuel assemblies, compared to 157 fuel assemblies for the ACPR1000. The HPR1000 reactor core is provided with lower average linear power density and higher thermal and hydraulic margin. In addition, benefiting from the higher thermal and hydraulic margin, the HPR1000 reactor core is capable of providing a potential rise of output power in the future, which presents significant economic advantages.

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 18 / 27

b) Reactor Coolant System

The design of Reactor Coolant System (RCP [RCS]) ensures the reactivity control provided by the reactor coolant water, the heat removal from the core to the secondary cooling side via reactor coolant, and the confinement of radioactive material. The design of RCP [RCS] has been improved based on the ACPR1000 design with due consideration of proven technique and the wide experience from the design, manufacture, construction, commissioning and operating feedback of the existing nuclear power plants. The following examples are the major modifications implemented during the development of the HPR1000 design:

- 1) Increase in the volume of Pressuriser (PZR). PZR controls the pressure of RCP [RCS] during normal operation and transient of the nuclear power plant. By increasing the volume of PZR, the pressure control ability is improved, which helps reduce the risk of overpressure and maintain the integrity of the primary pressure boundary.
- 2) Increase in the volume of secondary side Steam Generator (SG). SGs serve as the first means for heat removal from the reactor. By increasing the secondary side volume in SG, the inherent safety of the HPR1000 can be improved. The larger volume of SG contributes in improving the ability of temperature control and improving the autonomy of the SGs. For example, under Steam Generator Tube Rupture (SGTR) conditions, the larger secondary side steam volume of SGs can prevent the overflow of the affected SG, which improves the resilience to transients and accidents.
- 3) Eliminating the penetrations in the RPV lower head. The RPV is the highest reliability pressure boundary, and contains the reactor core, core support structure and water coolant, etc. In the ACPR1000 RPV design, measuring instrumentation adapters penetrates the lower head of the RPV, which may challenge the integrity of the pressure boundary and may increase the risk of leakage from the lower head. By considering the international research feedback, lower head penetrations are eliminated in HPR1000 design and the measuring instrumentation adapters are implemented on the closure head on the top of RPV, which improves the integrity of the highest reliability pressure boundary.

c) Safety Systems

In ACPR1000 design, the safety systems consist of two independent trains, but these two trains are connected with a common header. To improve the reliability of the safety systems, their configuration has been improved. Considering the case where one train of a safety system fails due to an initiating fault and the second train fails taking single failure criterion into account, a third redundant train is needed to ensure the required safety functions are performed reliably. As a

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 19 / 27

result, the independent, segregated three safety divisions are designed for design basis conditions with the capacity of 3×100%. The design of the independent, segregated three safety divisions meets the single failure criteria, demonstrates higher reliability of safety systems and reduces the risks related to common cause failures and internal hazards. The modifications involve Safety Injection System (RIS [SIS]), Emergency Boration System (RBS [EBS]), Emergency Feedwater System (ASG [EFWS]) and the related supporting systems, such as Component Cooling Water System (RRI [CCWS]), Essential Service Water System (SEC [ESWS]), Emergency Diesel Generator (EDG), etc.

For the safety features designed for design extension conditions, one train of safety features was designed for the ACPR1000. To improve resilience to design extension conditions, two independent and redundant trains of safety features have been implemented in the HPR1000 design. The safety features include Containment Heat Removal System (EHR [CHRS]), Extra Cooling System (ECS [ECS]), Pressuriser Safety Valve, etc. In addition, for the ACPR1000 design, the Secondary Passive Heat Removal System (ASP [SPHRS]) was added to cope with the total loss of feedwater and other design extension conditions. In HPR1000 design, the large capacity water tank of the ASP [SPHRS] was implemented to improve the autonomy of the nuclear power plant for 72 hours.

Details about the modifications to the safety systems are provided in *HPR1000 R&D History* document, Reference [5].

d) Electric Power

To adapt to the modifications implemented in the mechanical and process systems, and to ensure the reliability of electric power supplies, adaptive optimisations have been performed in electrical power systems.

Based on the ACPR1000 design, the two-train emergency power supply is modified to the independent three-train emergency power supply in HPR1000 design. The modifications in the electrical power systems improved the reliability of the power supply for the three-train safety systems.

To further improve the reliability of the power supply, an additional SBO diesel generator has been added to the HPR1000, which further improves the autonomy of the power supply for design extension conditions and the ability of dealing with SBO.

Considering the concept of DiD, the current electrical power system of the HPR1000 (FCG3) consist of the main power supply, auxiliary power supply, 3 emergency diesel generators, 2 SBO diesel generators and a UPS of 2 hours and another for 12 hours, which improves the reliability of the electrical power supply.

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 20 / 27

With the objective of further reducing the risk from human errors, the main control room design was optimised based on the ACPR1000 design. An Auxiliary Control Panel (ACP) is utilised in HPR1000 main control room design. The ACP works as the auxiliary monitoring and control means in case of unavailability of Plant Computer Information and Control System (KIC [PCICS]). The digital design of ACP provides a reduced size of the system compared with the conventional hardwired backup means provided for the ACPR1000, which facilitates the optimisation of the main control room layout design and provides advanced human-machine interface.

Aligning with the improvement made to the RPV through eliminating the lower head penetrations, the HPR1000 In-core Instrumentation System (RIC [IIS]) uses integrated instrumentation assemblies inserted from the top of the reactor pressure vessel to achieve the measurement of neutron flux, temperature and reactor coolant level, etc. In ACPR1000 design, the measurement of the parameters via RIC [IIS] was performed periodically and manually by inserting instrumentation assemblies from the lower head to the core. In HPR1000 design, the modified RIC [IIS] can perform the real time measurement of the core parameters. The improvements made to the RIC [IIS] help the operators to be aware of the plant parameters and the safety margin of the reactor core.

e) Hazard Protection

In addition to the system modifications implemented, the HPR1000 demonstrates a more comprehensive, detailed and systematic hazard analysis and hazard protection design compared with the ACPR1000, especially for the commercial aircraft crash, earthquake and external flooding hazards. For example, to prevent the effects of common cause failure on the safety systems due to internal hazards, the safety systems are implemented in segregated buildings; double-walled (internal and external) containment is set to protect against the external hazards, including large commercial aircraft crash.

Detailed descriptions about the modifications are provided in the *HPR1000 R&D History* document, Reference [5].

33.5.3 Conclusion on the Design Evolution

With the objective of further enhancing the design of each level of DiD and continuously improving the design reliability and nuclear safety, the historical development of HPR1000 represents a process of continuous improvement by considering RGP, OPEX and international research outcomes. As presented above, the continuous development of HPR1000 and the continuous risk reduction process have led to an optimised design with nuclear safety significantly increased, which forms the basis of UK HPR1000 design.

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 21 / 27

33.6 Preliminary ALARP Review of UK HPR1000

The ALARP review of the UK HPR1000 should follow the ALARP methodology presented in Sub-chapter 33.4. A summary of step 1 of the methodology used for the review of the historical design process has been presented in Sub-chapter 33.5. This sub-chapter provides the preliminary ALARP review of the UK HPR1000 following completion of step 2 to step 8. Summary of the outcomes from each step and the strategy for the steps that are not completed are provided.

33.6.1 Holistic Review: Systematic Review of UK HPR1000 Design

The main objective of the first part of the ALARP methodology, the holistic review, is to identify the areas for potential improvement by looking at the design of the whole plant. The review of the UK HPR1000 design includes the consistency review against RGP and OPEX (Step 2.1 of the ALARP methodology) and the insights of PSA (Step 2.2 of the ALARP methodology). Identification of the potential improvements is the basis to show that no further reasonable practicable improvements could be implemented.

33.6.1.1 Systematic Review of Design against RGP and OPEX

In each topic area of the UK HPR1000, RGP and relevant OPEX have been identified. The sub-chapters on Applicable Codes and Standards summarise the identification and analysis of applicable codes and standards that can be considered as RGP in the PCSR Chapters.

33.6.1.2 Insights from the PSA

Following the progress in fault analysis, especially the progress in PSA, the areas for potential improvements can be identified by considering the insights from the PSA.

33.6.2 Holistic Review: Collate Potential Improvements

A preliminary review against the RGP and OPEX has been performed. The gaps are mainly identified from the review against RGP/OPEX and to address the UK site characteristics. These gaps will be analysed to determine whether the design modification is necessary to reduce the risks during GDA Step 3 and Step 4. It should be noted that the identification and determination of potential improvements have not yet been finished and should be performed continuously, especially during the whole design of the UK HPR1000.

33.6.3 Strategy for Specific Reviews and Iterative Holistic Evaluation

To determine further reasonably practicable options to reduce the risks and improve safety, the identified potential improvements need to be investigated and, where appropriate, be incorporated into the design change process following the process proposed in the ALARP methodology (Part 2: specific review) and the GDA configuration management procedures, References [10] and [11].

The major design changes incorporated through the GDA process will be summarised in this sub-chapter, and their justification will be provided from a risk reduction perspective.

Once all of the potential improvements have been assessed, and a suitable (ALARP) option implemented for each potential improvement, the design shall subject to a further holistic review (Part 3 of the ALARP methodology).

33.7 Assessments of Radiation Protection Targets

Radiation protection targets have been set out in PCSR Chapter 4, for the UK HPR1000 in accordance with the nine numerical targets provided in the *SAPs*, Reference [7]. Assessments against radiation protection targets provide a quantitative assessment of the risk levels.

In this sub-chapter, summary of the assessment against radiation protection targets, which correspond to the numerical targets set out in the *SAPs*, will be provided. This review against these targets will also serve as an important source to indicate the areas of potential improvements. Demonstrating that the numerical targets are achievable is an essential element to support the claim that the nuclear safety risks are ALARP.

The radiation protection targets are in the form of dose levels, frequencies or risks. Each target is set in terms of a Basic Safety Level (BSL) and a Basic Safety Objective (BSO). The relationship between radiation protection targets and the numerical targets are clarified in this sub-chapter. The performance of the UK HPR1000 against the targets is summarised with the detailed supporting analysis presented in *PCER Chapter 7 Radiological Assessment*, Reference [8], and PCSR Chapters 12, 14 and 22.

33.7.1 Assessment of Radiation Protection Targets for Normal Operation

The radiation protection targets for normal operation correspond to the numerical targets 1, 2 and 3 in the *SAPs*:

a) Assessment of Target 1

Target 1 sets the targets and a legal limit for effective dose in a calendar year for any person on the site from sources of ionising radiation. The targets are presented in T-33.7-1. The assessment progress and working plan are presented in PCSR Chapter 22.

T-33.7-1 Target 1: Normal Operation-Any Person on the Site

Employees working with ionising radiation	
BSL (legal limit)	20 mSv
BSO	1 mSv
Other employees on the site	

Employees working with ionising radiation	
BSL	2 mSv
BSO	0.1 mSv

b) Assessment of Target 2

Target 2 sets the targets for average effective dose in a calendar year to defined groups of employees on the site working with ionising radiation. The targets are presented in T-33.7-2. Target 2 is under evaluation for UK HPR1000 with the progress and working plan presented in PCSR Chapter 22.

T-33.7-2 Target 2: Normal Operation-Any Group on the Site

BSL	10 mSv
BSO	0.5 mSv

c) Assessment of Target 3

Target 3 sets the target and the legal limit for effective dose in a calendar year for any person off the site from sources of ionising radiation originating on the site. The targets are presented in T-33.7-3. In *PCER Chapter 7 Radiological Assessment*, Reference [8], Target 3 of the *SAPs* has been interpreted and analysed by using the Best Available Technique (BAT) approach which is similar to the ALARP approach..

T-33.7-3 Target 3: Normal Operation-Any Person off the Site

BSL (legal limit)	1 mSv
BSO	0.02 mSv

33.7.2 Assessment of Radiation Protection Targets for Fault and Accident Condition

The radiation protection targets for fault and accident conditions correspond to numerical targets 4 to 9 in the *SAPs*:

a) Assessment of Target 4

Target 4 sets the targets for the effective dose received by any person arising from design basis fault sequence. The targets are presented in T-33.7-4. The assessment against Target 4 is still in progress and will be presented in Chapter 12.

T-33.7-4 Target 4: Design Basis Fault Sequences-Any Person

On site

BSL	20 mSv for initiating fault frequencies exceeding 1×10^{-3} pa
	200 mSv for initiating fault frequencies between 1×10^{-3} pa and 1×10^{-4} pa
	500 mSv for initiating fault frequencies between 1×10^{-4} pa and 1×10^{-5} pa
BSO	0.1 mSv
Off site	
BSL	1 mSv for initiating fault frequencies exceeding 1×10^{-3} pa
	10 mSv for initiating fault frequencies between 1×10^{-3} pa and 1×10^{-4} pa
	100 mSv for initiating fault frequencies between 1×10^{-4} pa and 1×10^{-5} pa
BSO	0.01 mSv

b) Assessment of Target 5

Target 5 gives the individual risk of death from accidents to any person on the site. The targets are presented in T-33.7-5. The ALARP assessment against Target 5 will be carried out and presented in Chapter 14.

T-33.7-5 Target 5: Individual Risk of Death from Accidents-Any Person on the Site

BSL	1×10^{-4} pa
BSO	1×10^{-6} pa

c) Assessment of Target 6

Target 6 gives the predicted frequency of any single accident in the facility, which could give doses to a person on the site. The targets are presented in the table T-33.7-6. Target 6 is under evaluation for the UK HPR1000 with the progress and working plan presented in PCSR Chapter 14.

T-33.7-6 Target 6: Frequency Dose Targets for Any Single Accident-Any Person on the Site

Effective dose (mSv)	Predicted frequency per annum	
	BSL	BSO
2-20	1×10^{-1}	1×10^{-3}
20-200	1×10^{-2}	1×10^{-4}
200-2000	1×10^{-3}	1×10^{-5}

Effective dose (mSv)	Predicted frequency per annum	
	BSL	BSO
>2000	1×10^{-4}	1×10^{-6}

d) Assessment of Target 7

Target 7 sets the targets for the individual risk of death to a person off the site, from accidents at the site resulting in exposure to ionising radiation. The targets are presented in T-33.7-7. Target 7 is supported by Target 8 in the form of a dose-frequency staircase derived from Target 7. The assessment against Target 7 is still in progress as the assessment against Target 8 is not accomplished. The assessment against Target 7 will be presented in Chapter 14.

T-33.7-7 Target 7: Individual Risk to People off the Site from Accidents

BSL	1×10^{-4} pa
BSO	1×10^{-6} pa

e) Assessment of Target 8

Target 8 sets the targets for the total predicted frequencies of accidents on an individual facility, which could give doses to a person off the site. The targets are presented in T-33.7-8. Numerical Target 8 is addressed in Chapter 14.

T-33.7-8 Target 8: Frequency Dose Targets for Accidents on an Individual Facility – Any Person off the Site

Effective Dose (mSv)	Total Predicted Frequency per Annum	
	BSL	BSO
0.1-1	1	1×10^{-2}
1-10	1×10^{-1}	1×10^{-3}
10-100	1×10^{-2}	1×10^{-4}
100-1000	1×10^{-3}	1×10^{-5}
>1000	1×10^{-4}	1×10^{-6}

f) Assessment of Target 9

Target 9 gives the targets for the total risk of 100 or more fatalities, either immediate or eventual, from accidents at the site resulting in exposure to ionising radiation. The targets are presented in T-33.7-9. Target 9 assesses the societal risk which may be caused by the severe accident of the facility. The assessment against Target 9 will be

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 26 / 27

presented in Chapter 14.

T-33.7-9 Target 9: Total Risk of 100 or More Fatalities

BSL	1×10^{-5} pa
BSO	1×10^{-7} pa

33.8 Concluding Remarks

Following the UK requirements, reducing risks to the levels that are ALARP should be performed continuously for the UK HPR1000.

To demonstrate that nuclear safety risks are reduced to the level that is ALARP, a suitable methodology has been established to support the review of the design and the identification and implementation of reasonably practicable options to reduce the risks. By applying the ALARP methodology, a historical review of the HPR1000 design has been provided to demonstrate that the development process of HPR1000 can lead to an optimised and balanced design. The review of UK HPR1000 design against RGP/OPEX is on-going with several gaps identified and collected in this chapter.

Following the GDA progress, the ALARP methodology will be applied to further identify potential improvements from systematic review of the design and from PSA insights, to perform the specific reviews for the identified potential improvements and to perform the holistic review to ensure that all reasonably practicable measures have been adopted and no further optimisation is appropriate for the design. The assessment of the radiation protection targets will be summarised to demonstrate that the nuclear safety risk will be reduced to the level that is ALARP.

33.9 References

- [1] The Stationery Office, Health and Safety at Work etc. Act 1974, 1974.
- [2] HSE, Reducing Risks, Protecting People, 2001.
- [3] HSE, The Tolerability of Risk from Nuclear Power Stations, 1992.
- [4] CGN, ALARP Methodology, GHX00100051DOZJ03GN, Revision B, April 2018.
- [5] CGN, HPR1000 R&D History, GHX99980001DXZJ01MD, August 2018.
- [6] CGN, General Safety Requirements, GHX00100017DOZJ03GN, Revision C, August 2018.
- [7] ONR, Safety Assessment Principles for Nuclear Facilities, Revision 0, November 2014.
- [8] GNS, Pre-Construction Environment Report Chapter 7 Radiological

UK HPR1000 GDA	Pre-Construction Safety Report Chapter 33 ALARP Evaluation	UK Protective Marking: Not Protectively Marked	
		Rev: 000	Page: 27 / 27

Assessment, HPR/GDA/PCER/0007, Revision 000, September 2018.

- [9] ONR, Guidance on the Demonstration of ALARP (As Low As Reasonably Practicable), NS-TAST-GD-005, Revision 9, March 2018.
- [10] CGN, Provisions on Configuration Management for UK HPR1000 Generic Design Assessment (GDA) Project, GH-40M-009, 2018.
- [11] CGN, Provisions on Configuration Change Management for UK HPR1000 Generic Design Assessment (GDA) Project, GH-40M-012, 2018.
- [12] Department of Energy and Climate Change, Funded Decommissioning Programme Guidance for New Nuclear Power Stations, December 2011.
- [13] NDA, Industry Guidance: Interim Storage of Higher Activity Waste Packages –Integrated Approach, Issue 3, January 2017.